



NOTE: IF SOIL EROSION OCCURS, SOIL EROSION CONTROL SHALL BE REQUIRED.

NOTE: 24-HOUR CUSTOMER NOTIFICATION REQUIRED FOR ALL SHUTOFFS.

NOTE: S/W ON NORTH SIDE OF MARYLAND DR. SHALL BE 5' EXCEPT AT D/WS. S/W WILL REDUCE TO 4' AT THE D/WS. TAPER S/W FOR TRANSITION AT THE D/WS.

RAMPS/SIDEWALKS AT THE NE CORNER OF 70TH ST. & MARYLAND DR. AND NW CORNER OF 68TH ST. & MARYLAND DR. SHALL MEET ADA STANDARDS. SEE S/W DETAILS SHEET 7 & 8.

CONTRACTOR TO LOCATE ALL UNDERGROUND UTILITIES BEFORE DIGGING. CALL IOWA ONE CALL PHONE: 1-800-292-8989

NEW 5' TO 4' S/W DETAIL (NO. SIDE)

NOTE: HAND SHAPING REQUIRED FOR TRANSITION FROM 5' TO 4' S/W AT D/W. ADJUST S/W TO ACCOMMODATE NO MORE THAN A 10% SLOPE FOR THE D/W APPROACH, AND MAINTAIN THE TARGET SLOPE FOR THE S/W

SCALE HORZ 1"=30'	DRAWN BY JW
VERT 1"=5'	CHECKED BY DA
DATE: 02/09/21	CHECKED BY DA

URBANDALE WATER UTILITY

MARYLAND DRIVE - 70TH STREET TO 68TH STREET

2021-2 WATER SYSTEM IMPROVEMENTS

SHEET	6
OF	9